









TRUSS SCHEDULE		
ELEMENT	DESCRIPTION	REGION
TOP CHORD	40x2.0 SHS	30x2.0 SHS
WEB	40x2.0 SHS	30x2.0 SHS
CHORD	40x2.0 SHS	30x2.0 SHS



- NOTES:**
1. WALL SHEET STEEL GRADE C300
 2. ROOF SHEETING 0.42BUT 'CUSTOM ORG. MIN 5 TENS PER CONNECTION PER SHEET & EQUIVALENT SPACING CIRCUMFERENTIAL TEK FINING TO TOP OF TANK
 3. ROOF SHEETING TO BE SIDE LAP FASTENED AT MAX 1.0m C/C
 4. ALL BOLTS GRADE M10 (8.8) ONLY.
 5. ROOF TRUSS STEEL GRADE C350
 6. MIN FLETT WELD SIZE OF 4mm

DESIGN CRITERIA
AS/NZS 1170.2 2002 (WIND ACTIONS)
REGION A & B
TERRAIN CATEGORY 2
IMPORTANCE LEVEL 2

Rapallo
WA SITE: www.rapallo.com.au
PH: (08) 9021 5100 FAX: (08) 9021 6001 Email: rapallo@rapallo.com.au
PO BOX 3190 STURDIS WA 6007 CONTRACT FLOOR 130 241 STREET STURDIS

Heritage Tanks Australia Pty Ltd
Head Office
26 Boulder Road
Malaga WA 6090
Tel: + 61 8 9248 6199
Fax: + 61 8 9248 6299

Heritage Tanks Australia Pty Ltd
P O Box 3382
Malaga DC 6945
Western Australia
www.heritagetanks.com.au
htan@heritagetanks.com.au

SCALE	AS SHOWN	DATE
DRAWN	AJC	13/01/11
DESIGNED		
APPROVED		
PROJECT MGR		

HERITAGE TANKS AUSTRALIA PTY LTD



NO	DATE	BY	DESCRIPTION
8	08/11/11	MANOR REVISIONS	
7	03/08/11	ISSUED FOR REFERENCE	
6			
5			
4			
3			
2			
1			

SCALE	AS SHOWN	DATE
DRAWN	AJC	13/01/11
DESIGNED		
APPROVED		
PROJECT MGR		

HERITAGE TANKS AUSTRALIA PTY LTD

13231-HGT250-S001

SHEET NO. 13231

REV. B